
Energy performance certificate (EPC)				
Unit 8 Somerville Court Trinity Way Adderbury	Energy rating	Valid until: 8 April 2031		
BANBURY OX17 3SN	D	Certificate number: 1226-3520-8075-0797-7234		
Property type		B1 Offices and Workshop businesses		
Total floor area		350 square metres		

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

 29 B

 If typical of the existing stock

 85 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	54.61
Primary energy use (kWh/m2 per year)	320

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/9020-0627-5358-6578-4478)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Gregg Woodall
Telephone	01608 682948
Email	info@greggwoodall.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/019776
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Gregg Woodall Associates
Employer address	Linholm, Front Street, Ilmington, CV36 4LB
Assessor's declaration	The assessor is not related to the owner of the
	property.
Date of assessment	7 April 2021
Date of certificate	9 April 2021